



Element, Unit C6, Emery Court, The Embankment Business Park, Heaton Mersey, Stockport, SK4 3GL
Your Element Contact: David Guy (+44 (0)7827 156 007)
E: david.guy@element.com

Stack Emissions Testing Report Commissioned by
Avon Metals Ltd

Installation Name & Address
Avon Metals Ltd
Ashville Road
Gloucester
GL2 5DA

PPC Permit: PPC Permit: EP/A2/001, VARIATION GC/16/00001/A2/V4

Stack Reference
A1 New GT

Dates of the Monitoring Campaign
13th - 14th April 2026

Job Reference Number
EMT15917

Report Written by
Jonathon Guy Team Leader MCERTS Level 2 MM 16 1388 TE1 TE2 TE3 TE4

Report Approved by
Donal O Faogain Technical Report Writer MCERTS Level 2 MM13 1259 TE1 TE2 TE3 TE4

Report Date
29th April 2026

Version
Version 1

Signature of Report Approver


CONTENTS

TITLE PAGE

CONTENTS

EXECUTIVE SUMMARY

Monitoring Objectives	3
Monitoring Results	4
Monitoring Dates & Times	5
Process Details	6
Monitoring & Analytical Methods	7
Summary of Sampling Deviations	7
Sampling Location	8
Plant Photos / Sample Points	9

APPENDIX 1 - Monitoring Personnel & List of Equipment

APPENDIX 2 - Raw Data, Sampling Equations & Charts

Opinions and interpretations expressed herein are outside the scope of Element's ISO 17025 accreditation.

This test report shall not be reproduced, except in full, without the written approval of Element.

Executive Summary

(Page 1 of 7)

MONITORING OBJECTIVES

Avon Metals Ltd, Gloucester

A1 New GT

13th - 14th April 2026

Overall Aim of the Monitoring Campaign

Element were commissioned by Avon Metals Ltd to carry out stack emissions testing on the A1 New GT at Gloucester.

The aim of the monitoring campaign was to demonstrate compliance with a set of emission limit values (ELVs) as specified in the Site's Permit.

Special Requirements

There were no special requirements.

Target Parameters

Total Particulate Matter, Hydrogen Chloride, Dioxins & Furans, Hydrogen Fluoride, Total VOCs (as Carbon)

Executive Summary

(Page 2 of 7)

MONITORING RESULTS

Avon Metals Ltd, Gloucester
A1 New GT
13th - 14th April 2026

where MU = Measurement Uncertainty associated with the Result

Parameter	Concentration				Mass Emission			
	Units	Result	MU +/-	Limit	Units	Result	MU +/-	Limit
Total Particulate Matter ¹	mg/m ³	0.49	0.45	5	g/hr	19.7	18.2	-
Hydrogen Chloride ¹	mg/m ³	0.048	0.0040	5	g/hr	1.9	0.25	-
Dioxins & Furans Upper Limit (worst case where <LOD = LOD)								
Dioxins & Furans (NATO I-TEQ) ¹	ng/m ³	0.0094	0.0019	0.10	µg/hr	0.38	0.085	-
Dioxins & Furans (WHO TEQ Humans / Mammals) ¹	ng/m ³	0.0084	0.0017	-	µg/hr	0.34	0.076	-
Dioxins & Furans (WHO TEQ Fish) ¹	ng/m ³	0.0092	0.0019	-	µg/hr	0.37	0.083	-
Dioxins & Furans (WHO TEQ Birds) ¹	ng/m ³	0.014	0.0028	-	µg/hr	0.56	0.13	-
Dioxins & Furans Lower Limit (best case where <LOD = 0)								
Dioxins & Furans (NATO I-TEQ) ¹	ng/m ³	0.0088	0.0018	-	µg/hr	0.35	0.079	-
Dioxins & Furans (WHO TEQ Humans / Mammals) ¹	ng/m ³	0.0075	0.0015	-	µg/hr	0.30	0.068	-
Dioxins & Furans (WHO TEQ Fish) ¹	ng/m ³	0.0083	0.0017	-	µg/hr	0.33	0.075	-
Dioxins & Furans (WHO TEQ Birds) ¹	ng/m ³	0.013	0.0026	-	µg/hr	0.52	0.12	-
Hydrogen Fluoride ¹	mg/m ³	0.025	0.0017	1	g/hr	1.0	0.12	-
Total VOCs (as Carbon) ¹	mg/m ³	7.2	0.44	10	g/hr	288	33.0	-
Water Vapour	% v/v	0.59	0.037					
Stack Gas Temperature	°C	52.0						
Stack Gas Velocity	m/s	10.8	0.92					
Volumetric Flow Rate (ACTUAL)	m ³ /hr	47781	4605					
Volumetric Flow Rate (REF) ¹	m ³ /hr	40185	3873					

NOTE: VOLUMETRIC FLOW RATE & VELOCITY DATA TAKEN FROM AN AVERAGE OF ALL OF THE ISOKINETIC RUNS.

¹ Reference Conditions (REF) are: 273K, 101.3kPa, dry gas.

Executive Summary

(Page 3 of 7)

MONITORING DATE(S) & TIMES

Avon Metals Ltd, Gloucester

A1 New GT

13th - 14th April 2026

Parameter	Units	Concentration	Units	Mass Emission	Sampling Date(s)	Sampling Times	Duration mins	
Total Particulate Matter	R1	mg/m ³	0.71	g/hr	28.7	13/04/2026	10:14 - 11:18	64
Total Particulate Matter	R2	mg/m ³	0.49	g/hr	19.8	13/04/2026	11:24 - 12:28	64
Total Particulate Matter	R3	mg/m ³	0.26	g/hr	10.6	13/04/2026	12:32 - 13:36	64
Hydrogen Chloride	R1	mg/m ³	0.029	g/hr	1.2	13/04/2026	10:14 - 11:18	64
Hydrogen Chloride	R2	mg/m ³	0.079	g/hr	3.2	13/04/2026	11:24 - 12:28	64
Hydrogen Chloride	R3	mg/m ³	0.036	g/hr	1.5	13/04/2026	12:32 - 13:36	64
Dioxins & Furans (NATO)	R1	ng/m ³	0.0094	µg/hr	0.38	14/04/2026	07:55 - 13:55	360
Hydrogen Fluoride	R1	mg/m ³	< 0.015	g/hr	< 0.61	13/04/2026	10:14 - 11:18	64
Hydrogen Fluoride	R2	mg/m ³	< 0.016	g/hr	< 0.66	13/04/2026	11:24 - 12:28	64
Hydrogen Fluoride	R3	mg/m ³	0.042	g/hr	1.7	13/04/2026	12:32 - 13:36	64
Total VOCs (as Carbon)	R1	mg/m ³	7.2	g/hr	288	13/04/2026	11:24 - 12:24	60
Velocity Traverse	R1					13/04/2026	09:50 - 10:00	

All results are expressed at the respective reference conditions.

Executive Summary
(Page 4 of 7)

PROCESS DETAILS

Avon Metals Ltd, Gloucester
A1 New GT
13th - 14th April 2026

Standard Operating Conditions

Parameter	Value
Process Status	Metal Casting
Capacity (of 100%) and Tonnes / Hour	N/A
Continuous or Batch Process	Continuous
Feedstock (if applicable)	Alluminium Alloy
Abatement System	Bag Filter
Abatement System Running Status	Running
Fuel	Alluminium Alloy
Plume Appearance	No plume visible

Executive Summary

(Page 5 of 7)

MONITORING & ANALYTICAL METHODS

Avon Metals Ltd, Gloucester

A1 New GT

13th - 14th April 2026

Parameter	Monitoring				Analysis				Overall Status	LOD (Average)
	Standard	Technical Procedure	Sampling Status	Testing Lab	Analytical Procedure	Analytical Technique	Analysis Status	Analysis Lab		
Total Particulate Matter	EN 13284-1	MD 001	MCERTS	EET	MD 103	Gravimetric	MCERTS	EET	MCERTS	0.23 mg/m ³
Hydrogen Chloride	EN 1911	MD 011	MCERTS	EET	MD 101	IC	MCERTS	EET	MCERTS	0.015 mg/m ³
Dioxins & Furans	EN 1948	MD 007	MCERTS	EET	PM137, TM201	GC-HRMS	MCERTS	ELD	MCERTS	0.0018 ng/m ³
Hydrogen Fluoride	CEN/TS 17340	MD 010	MCERTS	EET	MD 101	IC	MCERTS	EET	MCERTS	0.015 mg/m ³
Water Vapour	EN 14790	MD 005	MCERTS	EET	MD 005	Gravimetric	MCERTS	EET	MCERTS	0.10 % v/v
Total VOCs (as Carbon)	EN 12619:2013	MD 020	MCERTS	EET	Flame Ionisation Detection by Sick 3006				MCERTS	0.32 mg/m ³
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	MD 041	MCERTS	EET	Pitot Tube and Thermocouple				MCERTS	1.8 m/s

ANALYSIS LABORATORIES

(with short name reference as appears in the table above)

Element (Stockport Lab - EET)	ISO 17025 Accreditation Number: UKAS 4279
Element (Deeside Lab - ELD)	ISO 17025 Accreditation Number: UKAS 4225

SUMMARY OF SAMPLING DEVIATIONS

Parameter	Run	Deviation
Total Particulate Matter, Dioxins & Furans, Velocity & Vol. Flow Rate	All	One out of two sampling lines was used due to sampling location restrictions, however the number of sample points used on the available line were increased to the minimum required by the Standard

SUITABILITY OF SAMPLING LOCATION

Duct Characteristics

Parameter	Units	Value
Type	-	Circular
Depth	m	1.25
Width	m	-
Area	m ²	1.23
Port Depth	cm	10
Orientation of Duct	-	Vertical
Number of Ports	-	2
Sample Port Size	-	4" BSP

Location of Sampling Platform

General Platform Information	Value
Permanent / Temporary Platform	Permanent
Inside / Outside	Outside

Platform Details

EA Technical Guidance Note M1 / EN 15259 Platform Requirements	Value
Sufficient working area to manipulate probe and operate the measuring instruments	Yes
Platform has 2 levels of handrails (approx. 0.5m & 1.0m high)	Yes
Platform has vertical base boards (approx. 0.25m high)	Yes
Platform has chains / self closing gates at top of ladders	Yes
There are no obstructions present which hamper insertion of sampling equipment	Yes
Safe Access Available	Yes
Easy Access Available	Yes

Sampling Location / Platform Improvement Recommendations

The sampling location meets all the requirements specified in EA Guidance Note M1 and EN 15259, and therefore there are no improvement recommendations.

EN 15259 Homogeneity Test Requirements

There is no requirement to perform a EN 15259 Homogeneity Test on this Stack.

Sampling Plane Validation Criteria (from EN 15259)

Criteria in EN 15259	Units	Traverse 1	Required	Compliant
Lowest Differential Pressure	Pa	78.5	> 5 Pa	Yes
Mean Velocity	m/s	10.94	-	-
Lowest Gas Velocity	m/s	10.74	-	-
Highest Gas Velocity	m/s	11.07	-	-
Ratio of Above	: 1	1.03	< 3 : 1	Yes
Maximum Angle of Swirl	°	8.00	< 15°	Yes
No Local Negative Flow	-	Yes	-	Yes

PLANT PHOTOS


Photo 1



Photo 2



SAMPLE POINTS





APPENDICES

APPENDIX CONTENTS

APPENDIX 1 - Stack Emissions Monitoring Personnel, List of Equipment & Methods and Technical Procedures Used

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

STACK EMISSIONS MONITORING PERSONNEL

Position	Name	MCERTS Accreditation	MCERTS Number	Technical Endorsements
Team Leader	Jonathon Guy	MCERTS Level 2	MM 16 1388	TE1 TE2 TE3 TE4
Technician	Simon Dwyer	MCERTS Level 1	MM 23 1768	None

LIST OF EQUIPMENT

Extractive Sampling		Instrumental Analysers		Miscellaneous Items	
Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.
Control Box DGM (1)	CAT 7.998	SELECT Horiba Model (1)	-	Digital Manometer (1)	CAT 3.271
Control Box DGM (2)	-	SELECT Horiba Model (2)	-	Digital Manometer (2)	CAT 3.116
Box Thermocouples (1)	CAT 3.103	SELECT Servomex Model	-	Digital Temperature Meter	CAT 3.317
Box Thermocouples (2)	-	SELECT NOX Analyser/Convertor	-	Stopwatch	CAT 14.444
Umbilical (1)	CAT 3.103	ABB AO2020-URAS26	-	Barometer	CAT 13.93
Umbilical (2)	-	Testo 350 XL	-	Stack Thermocouple (1)	-
Oven Box (1)	CAT 12.41	SELECT Gas Conditioning	-	Stack Thermocouple (2)	-
Oven Box (2)	-	SELECT FTIR	-	Stack Thermocouple (3)	CAT 4.9941
Heated Probe (1)	-	Gasmert Sampling System	-	1m Heated Line (1)	-
Heated Probe (2)	-	Sick 3006	CAT 8.28	1m Heated Line (2)	-
Heated Probe (3)	CAT 5.84	M&C PSS	CAT 12.172	1m Heated Line (3)	-
S-Pitot (1)	-	Mass Flow Controller (1)	CAT 6.32	5m Heated Line (1)	-
S-Pitot (2)	CAT 21P.76, 21S.17	Mass Flow Controller (2)	CAT 6.33	15m Heated Line (1)	CAT 20.230
L-Pitot	-	Mass View (1)	-	20m Heated Line (1)	-
Site Balance	CAT 17.51	Mass View (2)	-	20m Heated Line (2)	-
500g / 1Kg Check Weights	CAT 17.51	SELECT Logger 1	CAT 11.107	Dual Channel Heater Controller	-
Last Impinger Arm	CAT 4.895, 4.896, 4.8	SELECT Logger 2	-	Single Channel Heater Controller	-
Callipers	CAT 23.78	Bioaerosols Temperature Logger	-	Laboratory Balance	CAT 1.18, 1.18a, 1.18b
Tubes Kit Thermocouple	-	Electronic Refrigerator	-	Tape Measure	CAT 16.99

METHODS & TECHNICAL PROCEDURES USED

Parameter	Standard	Technical Procedure
Total Particulate Matter	EN 13284-1	MD 001
Hydrogen Chloride	EN 1911	MD 011
Dioxins & Furans	EN 1948	MD 007
Hydrogen Fluoride	CEN/TS 17340	MD 010
Water Vapour	EN 14790	MD 005
Total VOCs (as Carbon)	EN 12619:2013	MD 020
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	MD 041

PRELIMINARY STACK SURVEY: CALCULATIONS

General Stack Details

Stack Details (from Traverse)	Units	Value
Stack Diameter / Depth, D	m	1.25
Stack Width, W	m	-
Stack Area, A	m ²	1.23
Average Stack Gas Temperature, T _a	°C	47.5
Average Stack Gas Pressure	mmH ₂ O	8.3
Average Stack Static Pressure, P _{static}	kPa	0.092
Average Barometric Pressure, P _b	kPa	101.1
Average Pitot Tube Calibration Coefficient, C _p	-	0.898

Stack Gas Composition & Molecular Weights

Component	Conc ppm	Conc Dry % v/v	Conc Wet % v/v	Volume Fraction r	Molar Mass M	Density kg/m ³ ρ	Conc kg/m ³ ρ _i
CO ₂ (Estimated)	-	0.06	0.06	0.0006	44.01	1.9635	0.00118
O ₂ (Estimated)	-	20.80	20.68	0.2080	32.00	1.4277	0.29696
N ₂	-	79.14	78.67	0.7914	28.01	1.2498	0.98913
Moisture (H ₂ O)	-	-	0.59	0.0059	18.02	0.8037	0.00476

Where: $p = M / 22.41$
 $p_i = r \times p$

Calculation of Stack Gas Densities

Determinand	Units	Result
Dry Density (STP), P _{STD}	kg/m ³	1.287
Wet Density (STP), P _{STW}	kg/m ³	1.284
Dry Density (Actual), P _{Actual}	kg/m ³	1.095
Average Wet Density (Actual), P _{ActualW}	kg/m ³	1.093

Where: P_{STD} = sum of component concentrations, kg/m³ (not including water vapour)
P_{STW} = sum of all wet concentrations / 100 x density, kg/m³ (including water vapour)
 $P_{Actual} = P_{STD} \times (T_{STP} / (P_{STP})) \times ((P_{static} + P_b) / T_a)$
 $P_{ActualW}$ (at each sampling point) = P_{STW} x (T_s / P_s) x (P_a / T_a)

Calculation of Stack Gas Volumetric Flowrate, Q

Duct gas flow conditions	Units	Actual	REF ¹
Temperature	°C	47.5	0.0
Total Pressure	kPa	101.2	101.3
Moisture	%	0.59	0.00

Gas Volumetric Flowrate (from Traverse)	Units	Result
Gas Volumetric Flowrate (Actual)	m ³ /hr	48353
Gas Volumetric Flowrate (STP, Wet)	m ³ /hr	41149
Gas Volumetric Flowrate (STP, Dry)	m ³ /hr	40905
Gas Volumetric Flowrate REF ¹	m ³ /hr	40905

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID)

(1 of 1)

Parameter	Units	Value
Date of Survey	-	13/04/2026
Time of Survey	-	09:50 - 10:00
Atmospheric Pressure	kPa	101.1
Average Stack Static Pressure	Pa	92
Result of Pitot Stagnation Test	-	Pass
Are Water Droplets Present?	-	No
Device Used	S-Type Pitot with Liquid Incline Manometer	

Parameter	Units	Value
Initial Pitot Leak Check	-	Pass
Final Pitot Leak Check	-	Pass
Orientation of Duct	-	Vertical
Pitot Tube, C _p	-	0.898
Number of Lines Available	-	2
Number of Lines Used	-	1

Traverse Point	Depth m	ΔP mmH ₂ O	Sampling Line A			
			Temp °C	Wet Density kg/m ³	Velocity m/s	Swirl °
STATIC (Units: Pa)		92.0				
Mean		8.3	47.5	1.093	10.94	
1	0.04	8.0	47.4	1.093	10.74	3.0
2	0.13	8.3	47.5	1.093	10.90	3.0
3	0.24	8.3	47.5	1.093	10.90	4.0
4	0.40	8.5	47.4	1.093	11.07	6.0
5	0.85	8.5	47.5	1.093	11.07	4.0
6	1.01	8.3	47.4	1.093	10.90	7.0
7	1.12	8.3	47.4	1.093	10.90	8.0
8	1.21	8.5	47.5	1.093	11.07	4.0

Sampling Line B - Restricted Access				
ΔP	Temp °C	Wet Density kg/m ³	Velocity m/s	Swirl °

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID) - MEASUREMENT UNCERTAINTY

(1 of 1)

Performance characteristics (Uncertainty Components)	Uncertainty	Value	Units
Standard Uncertainty on the coefficient of the Pitot Tube	$u(k)$	0.005	-
Standard Uncertainty associated with the mean local dynamic pressures	$u(\Delta p_i)$	2.027	Pa
- Resolution	$u(res)$	0.52154	
- Calibration	$u(cal)$	0.692	
- Drift	$u(drift)$	1.096	
- Lack of Fit	$u(fit)$	0.801	
- Overall corrections to dynamic measurements	$u(C_f)$	3.111	
Standard uncertainty associated with the molar mass of the gas	$u(M)$	0.00003	-
- $\varphi_{O_2,w}$	-	20.677	
- $\varphi_{CO_2,w}$	-	0.060	
- Oxygen, dry	$u(\phi_{O_2,d})$	0.637	
- Carbon Dioxide, dry	$u(\phi_{CO_2,d})$	0.002	
- Water Vapour	$u(\phi_{H_2O})$	0.030	
- Oxygen, wet	$u(\phi_{O_2,w})$	0.633	
- Carbon Dioxide, wet	$u(\phi_{CO_2,w})$	0.002	
Standard uncertainty associated with the stack temperature	$u(T_c)$	1.635	K
Standard uncertainty associated with the absolute pressure in the duct	$u(p_c)$	175.704	Pa
- Atmospheric Pressure	$u(p_{atm})$	175.692	
- Static Pressure	$u(p_{stat})$	2.027	
Standard uncertainty associated with the density in the duct	$u(\rho)$	0.00597	-
Standard uncertainty associated with the local velocities	$u(v_i)$	1.336	Pa
Standard uncertainty associated with the mean velocity	$u(\bar{v})$	0.475	m/s
Standard uncertainty associated with the mean velocity (95% Confidence)	$U_c(v)$	0.931	m/s
Standard uncertainty associated with the mean velocity (95% Confidence), relative	$U_{c,rel}(v)$	8.51	%
Standard uncertainty associated with the volume flow rate (95% Confidence)	$U_c(qV,w)$	4659.6	m ³ /hr
- $u^2(a)/a^2$	-	0.00053	
- $u^2(qV,w)/q^2V,w$	-	0.00242	
- $u^2(qV,w)$	-	5651784	
- $u(qV,w)$	-	2377.3	
Standard uncertainty associated with the volume flow rate (95% Confidence), relative	$U_{c,rel}(qV,w)$	9.64	%

TOTAL PARTICULATE MATTER: RESULTS SUMMARY

Avon Metals Ltd, Gloucester
A1 New GT

Sample Runs

Parameter	Units	Run 1	Run 2	Run 3	Mean
Concentration	mg/m ³	0.71	0.49	0.26	0.49
Uncertainty	±mg/m ³	0.45	0.46	0.44	0.45
Mass Emission	g/hr	28.7	19.8	10.6	19.7
Uncertainty	±g/hr	18.2	18.8	17.7	18.2

Parameter	Units	Run 1	Run 2	Run 3	Mean
Water Vapour	% v/v	0.073	0.13	0.46	0.22
Uncertainty	±% v/v	0.015	0.016	0.028	0.020

Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m ³	0.23	0.23

NOTE: Where the Balance Uncertainty / Limit of Detection is higher than the Blank concentration, the Balance Uncertainty / Limit of Detection concentration has been reported.

General Sampling Information

Parameter	Value
Standard	EN 13284-1
Technical Procedure	MD 001
Probe Material	Titanium
Filter Housing Material	Titanium
Positioning of Filter	In Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 2
Number of Sampling Points Used	8 / 8
Sample Point I.D.'s	A1, A2, A3, A4, A5, A6, A7, A8

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas.

TOTAL PARTICULATE MATTER: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	Run 2	Run 3
Absolute pressure of stack gas, P_s				
Barometric pressure, P _b	mmHg	762.8	762.8	762.8
Stack static pressure, P _{static}	mmH ₂ O	9.4	9.4	9.4
P _s = (P _b + (P _{static} / 13.6))	mmHg	763.5	763.5	763.5
Volume of water vapour collected, V_{wstd}				
Total mass collected in impingers (liquid trap)	g	-4.0	-2.1	-2.5
Total mass collected in impingers (silica trap)	g	4.6	3.1	6.3
Total mass of liquid collected, V _{lc}	g	0.6	1.0	3.8
V _{wstd} = (0.001246)(V _{lc})	m ³	0.0007	0.0012	0.0047
Volume of gas metered dry, V_{mstd}				
Volume of gas sample through gas meter, V _m	m ³	1.1670	1.1360	1.2140
Gas meter correction factor, Y _d	-	0.9310	0.9310	0.9310
Average dry gas meter temperature, T _m	°C	19.5	23.1	27.6
Average pressure drop across orifice, ΔH	mmH ₂ O	33.5	31.2	35.2
V _{mstd} = ((0.3592)(V _m (P _b + (ΔH/13.6))(Y _d)) / (T _m + 273))	m ³	1.0211	0.9817	1.0339
Moisture content, B_{wo} & R_{wv}				
B _{wo} = V _{wstd} / (V _{mstd} + V _{wstd})	m ³	0.0007	0.0013	0.0046
B _{wo} as a percentage	% v/v	0.07	0.13	0.46
Reported Water Vapour, checked with Tables in EN 14790, R _{wv}	% v/v	0.07	0.13	0.46
Volume of gas metered wet, V_{mstw}				
V _{mstw} = (V _{mstd})(100/(100 - R _{wv}))	m ³	1.0218	0.9829	1.0386
Volume of gas metered at Oxygen Reference Conditions, V_{mstd@X%O₂} & V_{mstw@X%O₂}				
IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction)	-	No	No	No
% wet oxygen measured in gas stream, ACT%O _{2w}	% v/v	N/A	N/A	N/A
% dry oxygen measured in gas stream, ACT%O _{2d}	% v/v	N/A	N/A	N/A
% oxygen reference condition, REF%O ₂	% v/v	N/A	N/A	N/A
O ₂ Reference Factor wet (O _{2REFw}) = (21 - REF%O ₂) / (21 - ACT%O _{2w})	-	N/A	N/A	N/A
O ₂ Reference Factor dry (O _{2REFd}) = (21 - REF%O ₂) / (21 - ACT%O _{2d})	-	N/A	N/A	N/A
V _{mstw@X%oxygen} = (V _{mstw}) / (O _{2REFw})	m ³	N/A	N/A	N/A
V _{mstd@X%oxygen} = (V _{mstd}) / (O _{2REFd})	m ³	N/A	N/A	N/A
Molecular weight of dry gas stream, M_d				
CO ₂ (Estimated)	% v/v	0.06	0.06	0.06
O ₂ (Estimated)	% v/v	20.80	20.80	20.80
Total	% v/v	20.86	20.86	20.86
N ₂	% v/v	79.14	79.14	79.14
M _d = 0.44(%CO ₂)+0.32(%O ₂)+0.28(%N ₂)	g/gmol	28.84	28.84	28.84
Molecular weight of stack gas (wet), M_s				
M _s = M _d (1 - (R _{wv} /100)) + 18(R _{wv} /100)	g/gmol	28.83	28.83	28.79
Velocity of stack gas, V_s				
Pitot tube velocity constant, K _p	-	34.97	34.97	34.97
Velocity pressure coefficient, C _p	-	0.90	0.90	0.90
Average of velocity heads, ΔP _{avg}	mmH ₂ O	8.06	7.61	8.39
Average square root of velocity heads, √ΔP	√mmH ₂ O	2.84	2.76	2.90
Average stack gas temperature, T _s	°C	46.4	54.2	52.0
V _s = ((K _p)(C _p)(√ΔP)(√T _s + 273)) / (√(M _s)(P _s))	m/s	10.74	10.56	11.06
Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO₂}), Dry@O_{2REF} (Q_{stdO₂})				
Area of stack, A _s	m ²	1.23	1.23	1.23
Q _a = (60)(A _s)(V _s)	m ³ /min	790.9	777.7	814.4
Conversion factor (K/mm.Hg), C _f	-	0.3592	0.3592	0.3592
Q _{stw} = ((Q _a)(P _s)(C _f)) / ((T _s) + 273)	m ³ /min	679.0	651.8	687.2
Q _{std} = ((Q _a)(P _s)(C _f)(1 - (R _{wv} /100))) / ((T _s) + 273)	m ³ /min	678.5	651.0	684.1
Q _{stwO₂} = ((Q _a)(P _s)(C _f)) / ((T _s) + 273) / (O _{2REFw})	m ³ /min	N/A	N/A	N/A
Q _{stdO₂} = ((Q _a)(P _s)(C _f)(1 - (R _{wv} /100))) / ((T _s) + 273) / (O _{2REFd})	m ³ /min	N/A	N/A	N/A
Percent isokinetic, %I				
Nozzle diameter, D _n	mm	5.98	5.98	5.98
Nozzle area, A _n	mm ²	28.09	28.09	28.09
Total sampling time, q	min	64	64	64
%I = (4.6398E ⁶)(T _s +273)(V _{mstd}) / (P _s)(V _s)(A _n)(q)(1 - (R _{wv} /100))	%	102.7	102.9	103.2

TOTAL PARTICULATE MATTER: SAMPLING DETAILS

Sample Runs

Parameter	Units	Run 1	Run 2	Run 3
Sampling Times	-	10:14 - 11:18	11:24 - 12:28	12:32 - 13:36
Sampling Dates	-	13/04/2026	13/04/2026	13/04/2026
Sampling Device	-	ISO	ISO	ISO
Volume Sampled (REF)	m ³	1.0211	0.9817	1.0339
Filter I.D. Number	-	47-128182	47-128183	47-128184
Start Filter Mass	g	0.15191	0.15137	0.15167
End Filter Mass	g	0.15202	0.15146	0.15177
Total Mass on Filter	g	0.00011	0.00009	0.00010
Probe Rinse I.D. Number	-	PR-47-128182	PR-47-128183	PR-47-128184
Start Probe Rinse Mass	g	2.91724	2.81580	2.86503
End Probe Rinse Mass	g	2.91786	2.81620	2.86520
Total Mass in Probe Rinse	g	0.00062	0.00039	0.00017
Total Mass Collected	mg	0.73	0.48	0.27
Calculated Concentration	mg/m ³	0.71	0.49	0.26
Balance Uncertainty / LOD	mg/m ³	0.23	0.23	0.22

Where: ISO stands for Manual Isokinetic Sampling Train

Blank Runs

Parameter	Units	Blank 1
Blank Dates	-	13/04/2026
Average Volume Sampled (REF)	m ³	1.0122
Filter I.D. Number	-	47-128196
Start Filter Mass	g	0.15275
End Filter Mass	g	0.15271
Total Mass on Filter	g	-0.00004
Probe Rinse I.D. Number	-	PR-47-128196
Start Probe Rinse Mass	g	2.91080
End Probe Rinse Mass	g	2.91078
Total Mass in Probe Rinse	g	-0.00002
Total Mass Collected	mg	-0.06
Calculated Concentration	mg/m ³	-0.06
Balance Uncertainty / LOD	mg/m ³	0.23

TOTAL PARTICULATE MATTER: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

Leak Test Results	Units	Run 1	Run 2	Run 3
Mean Sampling Rate	l/min	17.0	16.5	17.7
Pre-Sampling Leak Rate	l/min	0.12	0.12	0.12
Post-Sampling Leak Rate	l/min			
Allowable Leak Rate	l/min	0.36	0.36	0.36
Leak Test Acceptable	-	Yes	Yes	Yes

Water Droplets	Units	Run 1	Run 2	Run 3
Are Water Droplets Present	-	No	No	No

MU (Concurrent Water Vapour)	Units	Run 1	Run 2	Run 3
Measurement Uncertainty (MU)	%	20.3	12.9	6.2
Allowable MU	%	20.0	20.0	20.0
MU Acceptable	%	No	Yes	Yes

Silica Gel (Concurrent Water Vapour)	Units	Run 1	Run 2	Run 3
Less than 50% Faded	%	Yes	Yes	Yes

Isokinetic Criterion Compliance	Units	Run 1	Run 2	Run 3
Isokinetic Variation	%	102.7	102.9	103.2
Allowable Isokinetic Range	%	95 - 115	95 - 115	95 - 115
Isokineticity Acceptable	-	Yes	Yes	Yes

Weighing Uncertainty Criteria	Units	Run 1	Run 2	Run 3
Overall Weighing Uncertainty	± mg	0.33	0.33	0.33
Overall Weighing Uncertainty	± mg/m ³	0.32	0.33	0.31
ELV [Daily ELV for IED]	mg/m ³	5.00	5.00	5.00
Allowable Weighing Uncertainty	mg/m ³	0.25	0.25	0.25
Weighing Uncertainty Acceptable	-	No	No	No

Filter Temperatures	Units	Run 1	Run 2	Run 3
Pre-Conditioning Temperature	°C	180	180	180
Post-Conditioning Temperature	°C	160	160	160
Maximum Filter Temperature	°C	52	55	54

Test Conditions	Units	Run 1	Run 2	Run 3
Ambient Temperature Recorded?	-	Yes	Yes	Yes

TOTAL PARTICULATE MATTER: QUALITY ASSURANCE

(PAGE 2 OF 2)

Blank Runs

Leak Test Results	Units	Blank 1
Expected Sampling Rate	l/min	18.0
Pre-Sampling Leak Rate	l/min	0.13
Post-Sampling Leak Rate	l/min	
Allowable Leak Rate	l/min	0.36
Leak Test Acceptable	-	Yes

Validity of Blank vs ELV	Units	Blank 1
Allowable Blank	mg/m ³	0.5
Blank Acceptable	-	Yes

Acetone / Water Rinse Blank	Units	Blank
Acetone / Water Rinse Value	mg/l	2.7
Allowable Blank	mg/l	10
Blank Acceptable	-	Yes

Method Deviations

Nature of Deviation	Run Number			
	1	2	3	
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)				
One out of two sampling lines was used due to sampling location restrictions, however the number of sample points used on the available line were increased to the minimum required by the Standard	x	x	x	

TOTAL PARTICULATE MATTER: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value				Standard uncertainty				
	Symbol	Run 1	Run 2	Run 3	Symbol	Units	Run 1	Run 2	Run 3
Sampled Volume (Actual)	V _m	1.1670	1.1360	1.2140	uV _m	m ³	0.0233	0.0227	0.0243
Sampled Gas Temperature	T _m	292.5	296.1	300.6	uT _m	K	2.00	2.00	2.00
Sampled Gas Pressure	ρ _m	101.8	101.8	101.8	uρ _m	kPa	0.50	0.50	0.50
Sampled Gas Humidity	H _m	0.00	0.00	0.00	uH _m	% v/v	1.00	1.00	1.00
Leak	L	0.71	0.73	0.68	uL	%	-	-	-
Mass of Particulate	m	0.73	0.48	0.27	um	mg	0.23	0.23	0.23
Uncollected Mass	UCM	-0.06	-0.06	-0.06	uUCM	mg	-	-	-

Measured Quantities	Uncertainty as a Percentage				Requirement of Standard
	Units	Run 1	Run 2	Run 3	
Sampled Volume (Actual)	%	2.00	2.00	2.00	≤2%
Sampled Gas Temperature	%	0.68	0.68	0.67	≤1%
Sampled Gas Pressure	%	0.49	0.49	0.49	≤1%
Sampled Gas Humidity	%	1.00	1.00	1.00	≤1%
Leak	%	0.71	0.73	0.68	≤2%
Mass of Particulate	%	4.51	4.69	4.45	-
Uncollected Mass	%	-	-	-	-

Measured Quantities	Uncertainty in Measurement Units					Sensitivity Coefficient		
	Symbol	Units	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3
Sampled Volume (STP)	V _m	m ³	1.0211	0.9817	1.0339	0.70	0.50	0.26
Leak	L	mg/m ³	0.003	0.002	0.001	1.00	1.00	1.00
Mass of Particulate	L _r	mg	0.730	0.483	0.273	0.98	1.02	0.97
Uncollected Mass	UCM	mg	-0.03	-0.03	-0.03	0.98	1.02	0.97

Measured Quantities	Uncertainty in Result			
	Units	Run 1	Run 2	Run 3
Sampled Volume (STP)	mg/m ³	0.019	0.013	0.007
Leak	mg/m ³	0.0029	0.0021	0.0010
Mass of Particulate	mg/m ³	0.2253	0.2343	0.2225
Uncollected Mass	mg/m ³	-0.0320	-0.0333	-0.0316

Measured Quantities	Oxygen Correction Part of MU Budget			
	Units	Run 1	Run 2	Run 3
O ₂ Correction Factor	-	N/A	N/A	N/A
Stack Gas O ₂ Content	% v/v	N/A	N/A	N/A
MU for O ₂ Correction	-	N/A	N/A	N/A
Overall MU For O ₂ Measurement	%	N/A	N/A	N/A

Parameter	Units	Run 1	Run 2	Run 3
Combined uncertainty	mg/m ³	0.23	0.24	0.22
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.45	0.46	0.44
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A	N/A	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.45	0.46	0.44
Reported Uncertainty	mg/m ³	0.45	0.46	0.44
Expanded uncertainty (95% confidence), without Oxygen Correction	%	62.6	94.4	166.7
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A	N/A	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	62.6	94.4	166.7
Reported Uncertainty	%	62.6	94.4	166.7
Reported Uncertainty as % of ELV	%	9.0	9.3	8.8

HYDROGEN CHLORIDE: RESULTS SUMMARY

Avon Metals Ltd, Gloucester
A1 New GT

Sample Runs

Parameter	Units	Run 1	Run 2	Run 3	Mean
Concentration	mg/m ³	0.029	0.079	0.036	0.048
Uncertainty	±mg/m ³	0.0024	0.0065	0.0030	0.0040
Mass Emission	g/hr	1.2	3.2	1.5	1.9
Uncertainty	±g/hr	0.15	0.40	0.19	0.25

Parameter	Units	Run 1	Run 2	Run 3	Mean
Water Vapour	% v/v	0.07	0.13	0.46	0.22
Uncertainty	±% v/v	0.015	0.016	0.028	0.020

Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m ³	< 0.015	< 0.015

General Sampling Information

Parameter	Value
Standard	EN 1911
Technical Procedure	MD 011
Name of Analytical Laboratory	EET
Analytical Laboratory's Procedure	MD 101
ISO 17025 Accredited Analysis?	MCERTS
Date of Sample Analysis	16/04/2026
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Polyethylene
Absorption Solution	HPLC Grade Water
Positioning of Filter	In Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 2
Number of Sampling Points Used	8 / 8
Sample Point I.D.'s	A1, A2, A3, A4, A5, A6, A7, A8

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas.

HYDROGEN CHLORIDE: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	Run 2	Run 3
Absolute pressure of stack gas, P_s				
Barometric pressure, P _b	mmHg	762.8	762.8	762.8
Stack static pressure, P _{static}	mmH ₂ O	9.4	9.4	9.4
P _s = (P _b + (P _{static} / 13.6))	mmHg	763.5	763.5	763.5
Volume of water vapour collected, V_{wstd}				
Total mass collected in impingers (liquid trap)	g	-4.0	-2.1	-2.5
Total mass collected in impingers (silica trap)	g	4.6	3.1	6.3
Total mass of liquid collected, V _{lc}	g	0.6	1.0	3.8
V _{wstd} = (0.001246)(V _{lc})	m ³	0.0007	0.0012	0.0047
Volume of gas metered dry, V_{mstd}				
Volume of gas sample through gas meter, V _m	m ³	1.1670	1.1360	1.2140
Gas meter correction factor, Y _d	-	0.9310	0.9310	0.9310
Average dry gas meter temperature, T _m	°C	19.5	23.1	27.6
Average pressure drop across orifice, ΔH	mmH ₂ O	33.5	31.2	35.2
V _{mstd} = ((0.3592)(V _m (P _b + (ΔH/13.6))(Y _d)) / (T _m + 273))	m ³	1.0211	0.9817	1.0339
Moisture content, B_{wo} & R_{wv}				
B _{wo} = V _{wstd} / (V _{mstd} + V _{wstd})	m ³	0.0007	0.0013	0.0046
B _{wo} as a percentage	% v/v	0.07	0.13	0.46
Reported Water Vapour, checked with Tables in EN 14790, R _{wv}	% v/v	0.07	0.13	0.46
Volume of gas metered wet, V_{mstw}				
V _{mstw} = (V _{mstd})(100/(100 - R _{wv}))	m ³	1.0218	0.9829	1.0386
Volume of gas metered at Oxygen Reference Conditions, V_{mstd@X%O₂} & V_{mstw@X%O₂}				
IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction)	-	No	No	No
% wet oxygen measured in gas stream, ACT%O _{2w}	% v/v	N/A	N/A	N/A
% dry oxygen measured in gas stream, ACT%O _{2d}	% v/v	N/A	N/A	N/A
% oxygen reference condition, REF%O ₂	% v/v	N/A	N/A	N/A
O ₂ Reference Factor wet (O _{2REFw}) = (21 - REF%O ₂) / (21 - ACT%O _{2w})	-	N/A	N/A	N/A
O ₂ Reference Factor dry (O _{2REFd}) = (21 - REF%O ₂) / (21 - ACT%O _{2d})	-	N/A	N/A	N/A
V _{mstw@X%oxygen} = (V _{mstw}) / (O _{2REFw})	m ³	N/A	N/A	N/A
V _{mstd@X%oxygen} = (V _{mstd}) / (O _{2REFd})	m ³	N/A	N/A	N/A
Molecular weight of dry gas stream, M_d				
CO ₂ (Estimated)	% v/v	0.06	0.06	0.06
O ₂ (Estimated)	% v/v	20.80	20.80	20.80
Total	% v/v	20.86	20.86	20.86
N ₂	% v/v	79.14	79.14	79.14
M _d = 0.44(%CO ₂)+0.32(%O ₂)+0.28(%N ₂)	g/gmol	28.84	28.84	28.84
Molecular weight of stack gas (wet), M_s				
M _s = M _d (1 - (R _{wv} /100)) + 18(R _{wv} /100)	g/gmol	28.83	28.83	28.79
Velocity of stack gas, V_s				
Pitot tube velocity constant, K _p	-	34.97	34.97	34.97
Velocity pressure coefficient, C _p	-	0.90	0.90	0.90
Average of velocity heads, ΔP _{avg}	mmH ₂ O	8.06	7.61	8.39
Average square root of velocity heads, √ΔP	√mmH ₂ O	2.84	2.76	2.90
Average stack gas temperature, T _s	°C	46.4	54.2	52.0
V _s = ((K _p)(C _p)(√ΔP)(√T _s + 273)) / (√(M _s)(P _s))	m/s	10.74	10.56	11.06
Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO₂}), Dry@O_{2REF} (Q_{stdO₂})				
Area of stack, A _s	m ²	1.23	1.23	1.23
Q _a = (60)(A _s)(V _s)	m ³ /min	790.9	777.7	814.4
Conversion factor (K/mm.Hg), C _f	-	0.3592	0.3592	0.3592
Q _{stw} = ((Q _a)(P _s)(C _f)) / ((T _s) + 273)	m ³ /min	679.0	651.8	687.2
Q _{std} = ((Q _a)(P _s)(C _f)(1 - (R _{wv} /100))) / ((T _s) + 273)	m ³ /min	678.5	651.0	684.1
Q _{stwO₂} = ((Q _a)(P _s)(C _f)) / ((T _s) + 273) / (O _{2REFw})	m ³ /min	N/A	N/A	N/A
Q _{stdO₂} = ((Q _a)(P _s)(C _f)(1 - (R _{wv} /100))) / ((T _s) + 273) / (O _{2REFd})	m ³ /min	N/A	N/A	N/A
Percent isokinetic, %I				
Nozzle diameter, D _n	mm	5.98	5.98	5.98
Nozzle area, A _n	mm ²	28.09	28.09	28.09
Total sampling time, q	min	64	64	64
%I = (4.6398E ⁶)(T _s +273)(V _{mstd}) / (P _s)(V _s)(A _n)(q)(1 - (R _{wv} /100))	%	102.7	102.9	103.2

HYDROGEN CHLORIDE: SAMPLING DETAILS

Sample Runs

Parameter	Units	Run 1	Run 2	Run 3
Sampling Times	-	10:14 - 11:18	11:24 - 12:28	12:32 - 13:36
Sampling Dates	-	13/04/2026	13/04/2026	13/04/2026
Sampling Device	-	ISO	ISO	ISO
Volume Sampled (REF)	m ³	1.0211	0.9817	1.0339
Laboratory Result for Front Impingers	µg/ml	0.12	0.24	0.12
Laboratory Result for Back Impinger	µg/ml	0.05		
Volume in Front Impingers	ml	201.4	323.2	313.6
Volume in Back Impinger	ml	101.3		
Mass in Front Impingers	µg	24.2	77.6	37.6
Mass in Back Impinger	µg	5.1		
Total Mass Collected	µg	29.2	77.6	37.6
Calculated Concentration	mg/m ³	0.029	0.079	0.036

Where: ISO stands for Manual Isokinetic Sampling Train

Blank Runs

Parameter	Units	Blank 1
Blank Dates	-	13/04/2026
Average Volume Sampled (REF)	m ³	1.0122
Laboratory Result for Impingers	µg/ml	< 0.05
Volume in Impingers	ml	306.2
Total Mass Collected	µg	< 15.3
Calculated Concentration	mg/m ³	< 0.015

HYDROGEN CHLORIDE: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

Leak Test Results	Units	Run 1	Run 2	Run 3	
Mean Sampling Rate	l/min	17.0	16.5	17.7	
Pre-Sampling Leak Rate	l/min	0.12	0.12	0.12	
Post-Sampling Leak Rate	l/min	N/A	N/A	N/A	
Allowable Leak Rate	l/min	0.36	0.36	0.36	
Leak Test Acceptable	-	Yes	Yes	Yes	
Absorption Efficiency	Units	Run 1			
Absorption Efficiency	%	82.7			
Allowable Absorption Efficiency	%	N/A ¹			
Absorption Efficiency Acceptable	-	Yes ¹			
¹ The concentration in the last absorber was less than 5 times the analytical detection limit.					
Water Droplets	Units	Run 1	Run 2	Run 3	
Are Water Droplets Present	-	No	No	No	
MU (Concurrent Water Vapour)	Units	Run 1	Run 2	Run 3	
Measurement Uncertainty (MU)	%	20.3	12.9	6.2	
Allowable MU	%	20.0	20.0	20.0	
MU Acceptable	%	No	Yes	Yes	
Silica Gel (Concurrent Water Vapour)	Units	Run 1	Run 2	Run 3	
Less than 50% Faded	%	Yes	Yes	Yes	
Isokinetic Criterion Compliance	Units	Run 1	Run 2	Run 3	
Isokinetic Variation	%	102.7	102.9	103.2	
Allowable Isokinetic Range	%	95 - 115	95 - 115	95 - 115	
Isokineticity Acceptable	-	Yes	Yes	Yes	
Filter Temperatures	Units	Run 1	Run 2	Run 3	
Maximum Filter Temperature	°C	52	55	54	
Test Conditions	Units	Run 1	Run 2	Run 3	
Ambient Temperature Recorded?	-	Yes	Yes	Yes	

HYDROGEN CHLORIDE: QUALITY ASSURANCE

(PAGE 2 OF 2)

Blank Runs

Leak Test Results	Units	Blank 1	
Expected Sampling Rate	l/min	18.0	
Pre-Sampling Leak Rate	l/min	0.13	
Post-Sampling Leak Rate	l/min		
Allowable Leak Rate	l/min	0.36	
Leak Test Acceptable	-	Yes	
Validity of Blank vs ELV	Units	Blank 1	
Allowable Blank	mg/m ³	0.5	
Blank Acceptable	-	Yes	

Method Deviations

Nature of Deviation	Run Number			
	(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1	2	3

HYDROGEN CHLORIDE: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value				Standard uncertainty				
	Symbol	Run 1	Run 2	Run 3	Symbol	Units	Run 1	Run 2	Run 3
Sampled Volume (Actual)	V _m	1.1670	1.1360	1.2140	uV _m	m ³	0.0233	0.0227	0.0243
Sampled Gas Temperature	T _m	292.5	296.1	300.6	uT _m	K	2.00	2.00	2.00
Sampled Gas Pressure	ρ _m	101.8	101.8	101.8	uρ _m	kPa	0.50	0.50	0.50
Sampled Gas Humidity	H _m	0.00	0.00	0.00	uH _m	% v/v	1.00	1.00	1.00
Leak	L	0.71	0.73	0.68	uL	%	-	-	-
Laboratory Result	L _r	3.25	3.25	3.25	uL _r	%	-	-	-

Measured Quantities	Uncertainty as a Percentage				Requirement of Standard
	Units	Run 1	Run 2	Run 3	
Sampled Volume (Actual)	%	2.00	2.00	2.00	≤2%
Sampled Gas Temperature	%	0.68	0.68	0.67	≤1%
Sampled Gas Pressure	%	0.49	0.49	0.49	≤1%
Sampled Gas Humidity	%	1.00	1.00	1.00	≤1%
Leak	%	0.71	0.73	0.68	≤2%
Laboratory Result	%	3.25	3.25	3.25	No Requirement

Measured Quantities	Uncertainty in Measurement Units					Sensitivity Coefficient		
	Symbol	Units	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3
Sampled Volume (STP)	V _m	m ³	1.0211	0.9817	1.0339	0.028	0.080	0.035
Leak	L	mg/m ³	0.00012	0.00033	0.00014	1.00	1.00	1.00
Laboratory Result	L _r	mg/m ³	0.001	0.003	0.001	1.00	1.00	1.00

Measured Quantities	Uncertainty in Result			
	Units	Run 1	Run 2	Run 3
Sampled Volume (STP)	mg/m ³	0.0008	0.0021	0.0010
Leak	mg/m ³	0.0001	0.0003	0.0001
Laboratory Result	mg/m ³	0.0009	0.0026	0.0012

Measured Quantities	Oxygen Correction Part of MU Budget			
	Units	Run 1	Run 2	Run 3
O ₂ Correction Factor	-	N/A	N/A	N/A
Stack Gas O ₂ Content	% v/v	N/A	N/A	N/A
MU for O ₂ Correction	-	N/A	N/A	N/A
Overall MU For O ₂ Measurement	%	N/A	N/A	N/A

Parameter	Units	Run 1	Run 2	Run 3
Combined uncertainty	mg/m ³	0.0012	0.0033	0.0015
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.0024	0.0065	0.0030
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A	N/A	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.0024	0.0065	0.0030
Reported Uncertainty	mg/m ³	0.0024	0.0065	0.0030
Expanded uncertainty (95% confidence), without Oxygen Correction	%	8.2	8.3	8.3
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A	N/A	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	8.2	8.3	8.3
Reported Uncertainty	%	8.2	8.3	8.3
Reported Uncertainty as % of ELV	%	0.0	0.1	0.1

DIOXINS & FURANS: RESULTS SUMMARY

(PAGE 1 OF 4)

Avon Metals Ltd, Gloucester
A1 New GT

TEQ1 - UPPER LIMITS (worst case where <LOD = LOD)

Sample Runs (UPPER NATO I-TEQ)

Parameter	Units	Run 1	Mean
Concentration	ng/m ³	0.0094	0.0094
Uncertainty	±ng/m ³	0.0019	0.0019
Mass Emission	µg/hr	0.38	0.38
Uncertainty	±µg/hr	0.085	0.085

Sample Runs (UPPER WHO TEQ Humans / Mammals)

Parameter	Units	Run 1	Mean
Concentration	ng/m ³	0.0084	0.0084
Uncertainty	±ng/m ³	0.0017	0.0017
Mass Emission	µg/hr	0.34	0.34
Uncertainty	±µg/hr	0.076	0.076

Sample Runs (UPPER WHO TEQ Fish)

Parameter	Units	Run 1	Mean
Concentration	ng/m ³	0.0092	0.0092
Uncertainty	±ng/m ³	0.0019	0.0019
Mass Emission	µg/hr	0.37	0.37
Uncertainty	±µg/hr	0.083	0.083

Sample Runs (UPPER WHO TEQ Birds)

Parameter	Units	Run 1	Mean
Concentration	ng/m ³	0.0140	0.0140
Uncertainty	±ng/m ³	0.0028	0.0028
Mass Emission	µg/hr	0.56	0.56
Uncertainty	±µg/hr	0.13	0.13

DIOXINS & FURANS: RESULTS SUMMARY

(PAGE 2 OF 4)

Avon Metals Ltd, Gloucester
A1 New GT

TEQ2 - LOWER LIMITS (best case where <LOD = 0)

Sample Runs (LOWER NATO I-TEQ)

Parameter	Units	Run 1	Mean
Concentration	ng/m ³	0.0088	0.0088
Uncertainty	±ng/m ³	0.0018	0.0018
Mass Emission	µg/hr	0.35	0.35
Uncertainty	±µg/hr	0.079	0.079

Sample Runs (LOWER WHO TEQ Humans / Mammals)

Parameter	Units	Run 1	Mean
Concentration	ng/m ³	0.0075	0.0075
Uncertainty	±ng/m ³	0.0015	0.0015
Mass Emission	µg/hr	0.30	0.30
Uncertainty	±µg/hr	0.068	0.068

Sample Runs (LOWER WHO TEQ Fish)

Parameter	Units	Run 1	Mean
Concentration	ng/m ³	0.0083	0.0083
Uncertainty	±ng/m ³	0.0017	0.0017
Mass Emission	µg/hr	0.33	0.33
Uncertainty	±µg/hr	0.075	0.075

Sample Runs (LOWER WHO TEQ Birds)

Parameter	Units	Run 1	Mean
Concentration	ng/m ³	0.0130	0.0130
Uncertainty	±ng/m ³	0.0026	0.0026
Mass Emission	µg/hr	0.52	0.52
Uncertainty	±µg/hr	0.12	0.12

DIOXINS & FURANS: RESULTS SUMMARY

(PAGE 3 OF 4)

Avon Metals Ltd, Gloucester
A1 New GT

TEQ1 - UPPER LIMITS (worst case where <LOD = LOD)

Blank Runs (UPPER NATO I-TEQ)

Parameter	Units	Blank 1	Maximum
Concentration	ng/m ³	0.00043	0.00043

Blank Runs (UPPER WHO TEQ Humans / Mammals)

Parameter	Units	Blank 1	Maximum
Concentration	ng/m ³	0.00050	0.00050

Blank Runs (UPPER WHO TEQ Fish)

Parameter	Units	Blank 1	Maximum
Concentration	ng/m ³	0.00055	0.00055

Blank Runs (UPPER WHO TEQ Birds)

Parameter	Units	Blank 1	Maximum
Concentration	ng/m ³	0.00070	0.00070

TEQ2 - LOWER LIMITS (best case where <LOD = 0)

Blank Runs (LOWER NATO I-TEQ)

Parameter	Units	Blank 1	Maximum
Concentration	ng/m ³	0.000026	0.000026

Blank Runs (LOWER WHO TEQ Humans / Mammals)

Parameter	Units	Blank 1	Maximum
Concentration	ng/m ³	0.000023	0.000023

Blank Runs (LOWER WHO TEQ Fish)

Parameter	Units	Blank 1	Maximum
Concentration	ng/m ³	0.000016	0.000016

Blank Runs (LOWER WHO TEQ Birds)

Parameter	Units	Blank 1	Maximum
Concentration	ng/m ³	0.000016	0.000016

DIOXINS & FURANS: RESULTS SUMMARY

(PAGE 4 OF 4)

Avon Metals Ltd, Gloucester
A1 New GT

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	1.3	1.3
Uncertainty	±% v/v	0.072	0.072

General Sampling Information

Parameter	Value
Standard	EN 1948
Technical Procedure	MD 007
Name of Analytical Laboratory	ELD
Analytical Laboratory's Procedure	PM137, TM201
ISO 17025 Accredited Analysis?	MCERTS
Date of Sample Analysis	20/04/2026
Probe Material	Titanium
Filter Housing Material	Borosilicate Glass
Glassware Material	Borosilicate Glass
Absorption Material	XAD-2
Positioning of Filter	Out Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 2
Number of Sampling Points Used	8 / 8
Sample Point I.D.'s	A1, A2, A3, A4, A5, A6, A7, A8

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas.

DIOXINS & FURANS: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	
Absolute pressure of stack gas, P_s			
Barometric pressure, P _b	mmHg	760.6	
Stack static pressure, P _{static}	mmH ₂ O	9.4	
P _s = (P _b + (P _{static} / 13.6))	mmHg	761.3	
Volume of water vapour collected, V_{wstd}			
Total mass collected in impingers (liquid trap)	g	23.7	
Total mass collected in impingers (silica trap)	g	38.9	
Total mass of liquid collected, V _{lc}	g	62.6	
V _{wstd} = (0.001246)(V _{lc})	m ³	0.0780	
Volume of gas metered dry, V_{mstd}			
Volume of gas sample through gas meter, V _m	m ³	6.5730	
Gas meter correction factor, Y _d	-	0.9310	
Average dry gas meter temperature, T _m	°C	19.0	
Average pressure drop across orifice, ΔH	mmH ₂ O	32.1	
V _{mstd} = ((0.3592)(V _m (P _b + (ΔH/13.6))(Y _d)) / (T _m + 273))	m ³	5.7440	
Moisture content, B_{wo} & R_{wv}			
B _{wo} = V _{wstd} / (V _{mstd} + V _{wstd})	m ³	0.0134	
B _{wo} as a percentage	% v/v	1.34	
Reported Water Vapour, checked with Tables in EN 14790, R _{wv}	% v/v	1.34	
Volume of gas metered wet, V_{mstw}			
V _{mstw} = (V _{mstd})(100/(100 - R _{wv}))	m ³	5.8220	
Volume of gas metered at Oxygen Reference Conditions, V_{mstd@X%O₂} & V_{mstw@X%O₂}			
IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction)	-	No	
% wet oxygen measured in gas stream, ACT%O _{2w}	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O _{2d}	% v/v	N/A	
% oxygen reference condition, REF%O ₂	% v/v	N/A	
O ₂ Reference Factor wet (O _{2REFw}) = (21 - REF%O ₂) / (21 - ACT%O _{2w})	-	N/A	
O ₂ Reference Factor dry (O _{2REFd}) = (21 - REF%O ₂) / (21 - ACT%O _{2d})	-	N/A	
V _{mstw@X%oxygen} = (V _{mstw}) / (O _{2REFw})	m ³	N/A	
V _{mstd@X%oxygen} = (V _{mstd}) / (O _{2REFd})	m ³	N/A	
Molecular weight of dry gas stream, M_d			
CO ₂ (Estimated)	% v/v	0.06	
O ₂ (Estimated)	% v/v	20.80	
Total	% v/v	20.86	
N ₂	% v/v	79.14	
M _d = 0.44(%CO ₂)+0.32(%O ₂)+0.28(%N ₂)	g/gmol	28.84	
Molecular weight of stack gas (wet), M_s			
M _s = M _d (1 - (R _{wv} /100)) + 18(R _{wv} /100)	g/gmol	28.70	
Velocity of stack gas, V_s			
Pitot tube velocity constant, K _p	-	34.97	
Velocity pressure coefficient, C _p	-	0.90	
Average of velocity heads, ΔP _{avg}	mmH ₂ O	8.10	
Average square root of velocity heads, √ΔP	√mmH ₂ O	2.85	
Average stack gas temperature, T _s	°C	61.7	
V _s = ((K _p)(C _p)(√ΔP)(√T _s + 273)) / (√(M _s)(P _s))	m/s	11.07	
Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO₂}), Dry@O_{2REF} (Q_{stdO₂})			
Area of stack, A _s	m ²	1.23	
Q _a = (60)(A _s)(V _s)	m ³ /min	814.7	
Conversion factor (K/mm.Hg), C _f	-	0.3592	
Q _{stw} = ((Q _a)(P _s)(C _f)) / ((T _s) + 273)	m ³ /min	665.7	
Q _{std} = ((Q _a)(P _s)(C _f)(1 - (R _{wv} /100))) / ((T _s) + 273)	m ³ /min	656.8	
Q _{stwO₂} = ((Q _a)(P _s)(C _f)) / ((T _s) + 273) / (O _{2REFw})	m ³ /min	N/A	
Q _{stdO₂} = ((Q _a)(P _s)(C _f)(1 - (R _{wv} /100))) / ((T _s) + 273) / (O _{2REFd})	m ³ /min	N/A	
Percent isokinetic, %I			
Nozzle diameter, D _n	mm	5.98	
Nozzle area, A _n	mm ²	28.09	
Total sampling time, q	min	360	
%I = (4.6398E ⁶)(T _s +273)(V _{mstd}) / (P _s)(V _s)(A _n)(q)(1 - (R _{wv} /100))	%	106.1	

DIOXINS & FURANS: SAMPLING DETAILS

RUN 1

Parameter	Units	Value
Sampling Times	-	07:55 - 13:55
Sampling Dates	-	14/04/2026
Sampling Device	-	ISO
Volume Sampled (REF)	m ³	5.7440

Where: ISO stands for Manual Isokinetic Sampling Train

Parameter	Units	Result	DL	NATO I-TEQ		WHO Humans / Mammals		WHO Fish		WHO Birds		% Rec
				TEQ1	TEQ2	TEQ1	TEQ2	TEQ1	TEQ2	TEQ1	TEQ2	
2378-TCDD	ng	ND	0.0018	0.0018	0.0000	0.0018	0.0000	0.0018	0.0000	0.0018	0.0000	84
12378-PeCDD	ng	ND	0.0036	0.0018	0.0000	0.0036	0.0000	0.0036	0.0000	0.0036	0.0000	80
123478-HxCDD	ng	0.0118	0.0056	0.0012	0.0012	0.0012	0.0012	0.0059	0.0059	0.0006	0.0006	88
123678-HxCDD	ng	0.0265	0.0057	0.0026	0.0026	0.0026	0.0026	0.0003	0.0003	0.0003	0.0003	87
123789-HxCDD	ng	0.0216	0.0058	0.0022	0.0022	0.0022	0.0022	0.0002	0.0002	0.0022	0.0022	-
1234678-HPeCDD	ng	0.2366	0.0020	0.0024	0.0024	0.0024	0.0024	0.0002	0.0002	0.0002	0.0002	83
OCDD	ng	0.3004	0.0037	0.0003	0.0003	0.0001	0.0001	0.0000	0.0000	0.0000	0.0000	80
Total Dioxins	ng	0.5969	-	0.0123	0.0087	0.0139	0.0084	0.0120	0.0066	0.0087	0.0033	-
2378-TCDF	ng	0.0137	0.0031	0.0014	0.0014	0.0014	0.0014	0.0007	0.0007	0.0137	0.0137	70
12378-PeCDF	ng	0.0145	0.0047	0.0007	0.0007	0.0004	0.0004	0.0007	0.0007	0.0014	0.0014	104
23478-PeCDF	ng	0.0336	0.0046	0.0168	0.0168	0.0101	0.0101	0.0168	0.0168	0.0336	0.0336	76
123478-HxCDF	ng	0.0362	0.0049	0.0036	0.0036	0.0036	0.0036	0.0036	0.0036	0.0036	0.0036	83
123678-HxCDF	ng	0.0398	0.0049	0.0040	0.0040	0.0040	0.0040	0.0040	0.0040	0.0040	0.0040	80
234678-HxCDF	ng	0.0803	0.0055	0.0080	0.0080	0.0080	0.0080	0.0080	0.0080	0.0080	0.0080	74
123789-HxCDF	ng	0.0373	0.0072	0.0037	0.0037	0.0037	0.0037	0.0037	0.0037	0.0037	0.0037	101
1234678-HPeCDF	ng	0.2746	0.0019	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	70
1234789-HPeCDF	ng	0.0607	0.0024	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	88
OCDF	ng	0.2515	0.0030	0.0003	0.0003	0.0001	0.0001	0.0000	0.0000	0.0000	0.0000	70
Total Furans	ng	0.8422	-	0.0419	0.0419	0.0347	0.0347	0.0410	0.0410	0.0715	0.0715	-
Totals	ng	1.4391	-	0.0541	0.0505	0.0485	0.0431	0.0530	0.0476	0.0802	0.0748	-
Total Concentration	ng/m ³	-	-	0.0094	0.0088	0.0084	0.0075	0.0092	0.0083	0.0140	0.0130	-
Limit of Detection	ng/m ³	-	-	0.0018	-	0.0020	-	0.0023	-	0.0029	-	-

Where: ND stands for Non Detected
DL stands for Analytical Detection Limit
TEQ1 refers to Non Detected Congeners at the Detection Limit
TEQ2 refers to Non Detected Congeners at Zero
% Rec stands for the Recovery Percentage of the Sample

DIOXINS & FURANS: SAMPLING DETAILS

(Continued)

BLANK 1

Parameter	Units	Value
Sampling Dates	-	14/04/2026
Sampling Device	-	ISO
Average Volume Sampled (REF)	m ³	5.7440

Where: ISO stands for Manual Isokinetic Sampling Train

Parameter	Units	Result	DL	NATO I-TEQ		WHO Humans / Mammals		WHO Fish		WHO Birds		% Rec
				TEQ1	TEQ2	TEQ1	TEQ2	TEQ1	TEQ2	TEQ1	TEQ2	
2378-TCDD	ng	ND	0.0006	0.0006	0.0000	0.0006	0.0000	0.0006	0.0000	0.0006	0.0000	95
12378-PeCDD	ng	ND	0.0012	0.0006	0.0000	0.0012	0.0000	0.0012	0.0000	0.0012	0.0000	88
123478-HxCDD	ng	ND	0.0010	0.0001	0.0000	0.0001	0.0000	0.0005	0.0000	0.0001	0.0000	92
123678-HxCDD	ng	ND	0.0010	0.0001	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000	95
123789-HxCDD	ng	ND	0.0010	0.0001	0.0000	0.0001	0.0000	0.0000	0.0000	0.0001	0.0000	-
1234678-HPeCDD	ng	0.0040	0.0007	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	90
OCDD	ng	0.0122	0.0013	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	82
Total Dioxins	ng	0.0162	-	0.0015	0.0001	0.0020	0.0000	0.0022	0.0000	0.0019	0.0000	-
2378-TCDF	ng	ND	0.0009	0.0001	0.0000	0.0001	0.0000	0.0000	0.0000	0.0009	0.0000	80
12378-PeCDF	ng	ND	0.0008	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0001	0.0000	92
23478-PeCDF	ng	ND	0.0008	0.0004	0.0000	0.0002	0.0000	0.0004	0.0000	0.0008	0.0000	86
123478-HxCDF	ng	ND	0.0008	0.0001	0.0000	0.0001	0.0000	0.0001	0.0000	0.0001	0.0000	88
123678-HxCDF	ng	ND	0.0009	0.0001	0.0000	0.0001	0.0000	0.0001	0.0000	0.0001	0.0000	88
234678-HxCDF	ng	ND	0.0009	0.0001	0.0000	0.0001	0.0000	0.0001	0.0000	0.0001	0.0000	80
123789-HxCDF	ng	ND	0.0012	0.0001	0.0000	0.0001	0.0000	0.0001	0.0000	0.0001	0.0000	93
1234678-HPeCDF	ng	0.0064	0.0009	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	76
1234789-HPeCDF	ng	0.0019	0.0011	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	81
OCDF	ng	0.0150	0.0019	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	75
Total Furans	ng	0.0233	-	0.0010	0.0001	0.0008	0.0001	0.0009	0.0001	0.0022	0.0001	-
Totals	ng	0.0395	-	0.0025	0.0001	0.0028	0.0001	0.0032	0.0001	0.0040	0.0001	-
Total Concentration	ng/m ³	-	-	0.0004	0.0000	0.0005	0.0000	0.0005	0.0000	0.0007	0.0000	-

Where: ND stands for Non Detected
DL stands for Analytical Detection Limit
TEQ1 refers to Non Detected Congeners at the Detection Limit
TEQ2 refers to Non Detected Congeners at Zero
% Rec stands for the Recovery Percentage of the Sample

DIOXINS & FURANS: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

Leak Test Results	Units	Run 1
Mean Sampling Rate	l/min	17.0
Pre-Sampling Leak Rate	l/min	0.14
Post-Sampling Leak Rate	l/min	0.14
Allowable Leak Rate	l/min	0.85
Leak Test Acceptable	-	Yes

Water Droplets	Units	Run 1
Are Water Droplets Present	-	No

MU (Concurrent Water Vapour)	Units	Run 1
Measurement Uncertainty (MU)	%	5.3
Allowable MU	%	20.0
MU Acceptable	%	Yes

Silica Gel (Concurrent Water Vapour)	Units	Run 1
Less than 50% Faded	%	Yes

Isokinetic Criterion Compliance	Units	Run 1
Isokinetic Variation	%	106.1
Allowable Isokinetic Range	%	95 - 115
Isokineticity Acceptable	-	Yes

Filter Temperatures	Units	Run 1
Maximum Filter Temperature	°C	120
Maximum Allowable Temperature	°C	125
Temperature Acceptable	-	Yes

Condenser Exit Temperature	Units	Run 1
Maximum Temperature Recorded	°C	16
Maximum Allowable Temperature	°C	20
Exit Temperature Acceptable	-	Yes

Test Conditions	Units	Run 1
Ambient Temperature Recorded?	-	Yes

DIOXINS & FURANS: QUALITY ASSURANCE

(PAGE 2 OF 2)

Blank Runs

Leak Test Results	Units	Blank 1	
Expected Sampling Rate	l/min	18.0	
Sampling Leak Rate	l/min	0.15	
Allowable Leak Rate	l/min	0.90	
Leak Test Acceptable	-	Yes	

Validity of NATO I-TEQ Blank vs ELV	Units	Blank 1	
Allowable Blank	ng/m ³	0.010	
Blank Acceptable	-	Yes	

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
One out of two sampling lines was used due to sampling location restrictions, however the number of sample points used on the available line were increased to the minimum required by the Standard	x

DIOXINS & FURANS (NATO I-TEQ): MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (Actual)	V _m	6.5730	uV _m	m ³	0.1315
Sampled Gas Temperature	T _m	292.0	uT _m	K	2.00
Sampled Gas Pressure	ρ _m	101.5	uρ _m	kPa	0.50
Sampled Gas Humidity	H _m	0.00	uH _m	% v/v	1.00
Leak	L	0.82	uL	%	-
Laboratory Result	L _r	10.0	uL _r	%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (Actual)	%	2.00	≤2%
Sampled Gas Temperature	%	0.69	≤1%
Sampled Gas Pressure	%	0.49	≤1%
Sampled Gas Humidity	%	1.00	≤1%
Leak	%	0.82	≤5%
Laboratory Result	%	10.0	No Requirement

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient	
	Symbol	Units	Run 1	Run 1	
Sampled Volume (STP)	V _m	m ³	5.7440	0.002	
Leak	L	ng/m ³	0.0000	1.00	
Laboratory Result	L _r	ng/m ³	0.0009	1.00	

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	ng/m ³	0.0002
Leak	ng/m ³	0.0000
Laboratory Result	ng/m ³	0.0009

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O ₂ Correction Factor	-	N/A
Stack Gas O ₂ Content	% v/v	N/A
MU for O ₂ Correction	-	N/A
Overall MU For O ₂ Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	ng/m ³	0.0010
Expanded uncertainty (95% confidence), without Oxygen Correction	ng/m ³	0.0019
Expanded uncertainty (95% confidence), with Oxygen Correction	ng/m ³	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	ng/m ³	0.0019
Reported Uncertainty	ng/m ³	0.0019
Expanded uncertainty (95% confidence), without Oxygen Correction	%	20.3
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	20.3
Reported Uncertainty	%	20.3
Reported Uncertainty as % of ELV	%	1.9

HYDROGEN FLUORIDE: RESULTS SUMMARY

Avon Metals Ltd, Gloucester
A1 New GT

Sample Runs

Parameter	Units	Run 1	Run 2	Run 3	Mean
Concentration	mg/m ³	< 0.015	< 0.016	0.042	0.025
Uncertainty	±mg/m ³	0.0011	0.0012	0.0030	0.0017
Mass Emission	g/hr	< 0.61	< 0.66	1.7	1.0
Uncertainty	±g/hr	0.07	0.08	0.20	0.12

NOTE: Where the maximum Blank concentration is higher than the Sample concentration, the Blank concentration has been reported.

Parameter	Units	Run 1	Run 2	Run 3	Mean
Water Vapour	% v/v	0.073	0.13	0.46	0.22
Uncertainty	±% v/v	0.015	0.016	0.028	0.020

Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m ³	< 0.015	< 0.015

General Sampling Information

Parameter	Value
Standard	CEN/TS 17340
Technical Procedure	MD 010
Name of Analytical Laboratory	EET
Analytical Laboratory's Procedure	MD 101
ISO 17025 Accredited Analysis?	MCERTS
Date of Sample Analysis	16/04/2026
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Polyethylene
Absorption Solution	HPLC Grade Water
Positioning of Filter	In Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 2
Number of Sampling Points Used	8 / 8
Sample Point I.D.'s	A1, A2, A3, A4, A5, A6, A7, A8

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas.

HYDROGEN FLUORIDE: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	Run 2	Run 3
Absolute pressure of stack gas, P_s				
Barometric pressure, P _b	mmHg	762.8	762.8	762.8
Stack static pressure, P _{static}	mmH ₂ O	9.4	9.4	9.4
P _s = (P _b + (P _{static} / 13.6))	mmHg	763.5	763.5	763.5
Volume of water vapour collected, V_{wstd}				
Total mass collected in impingers (liquid trap)	g	-4.0	-2.1	-2.5
Total mass collected in impingers (silica trap)	g	4.6	3.1	6.3
Total mass of liquid collected, V _{lc}	g	0.6	1.0	3.8
V _{wstd} = (0.001246)(V _{lc})	m ³	0.0007	0.0012	0.0047
Volume of gas metered dry, V_{mstd}				
Volume of gas sample through gas meter, V _m	m ³	1.1670	1.1360	1.2140
Gas meter correction factor, Y _d	-	0.9310	0.9310	0.9310
Average dry gas meter temperature, T _m	°C	19.5	23.1	27.6
Average pressure drop across orifice, ΔH	mmH ₂ O	33.5	31.2	35.2
V _{mstd} = ((0.3592)(V _m (P _b + (ΔH/13.6))(Y _d)) / (T _m + 273))	m ³	1.0211	0.9817	1.0339
Moisture content, B_{wo} & R_{wv}				
B _{wo} = V _{wstd} / (V _{mstd} + V _{wstd})	m ³	0.0007	0.0013	0.0046
B _{wo} as a percentage	% v/v	0.07	0.13	0.46
Reported Water Vapour, checked with Tables in EN 14790, R _{wv}	% v/v	0.07	0.13	0.46
Volume of gas metered wet, V_{mstw}				
V _{mstw} = (V _{mstd})(100/(100 - R _{wv}))	m ³	1.0218	0.9829	1.0386
Volume of gas metered at Oxygen Reference Conditions, V_{mstd@X%O₂} & V_{mstw@X%O₂}				
IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction)	-	No	No	No
% wet oxygen measured in gas stream, ACT%O _{2w}	% v/v	N/A	N/A	N/A
% dry oxygen measured in gas stream, ACT%O _{2d}	% v/v	N/A	N/A	N/A
% oxygen reference condition, REF%O ₂	% v/v	N/A	N/A	N/A
O ₂ Reference Factor wet (O _{2REFw}) = (21 - REF%O ₂) / (21 - ACT%O _{2w})	-	N/A	N/A	N/A
O ₂ Reference Factor dry (O _{2REFd}) = (21 - REF%O ₂) / (21 - ACT%O _{2d})	-	N/A	N/A	N/A
V _{mstw@X%oxygen} = (V _{mstw}) / (O _{2REFw})	m ³	N/A	N/A	N/A
V _{mstd@X%oxygen} = (V _{mstd}) / (O _{2REFd})	m ³	N/A	N/A	N/A
Molecular weight of dry gas stream, M_d				
CO ₂ (Estimated)	% v/v	0.06	0.06	0.06
O ₂ (Estimated)	% v/v	20.80	20.80	20.80
Total	% v/v	20.86	20.86	20.86
N ₂	% v/v	79.14	79.14	79.14
M _d = 0.44(%CO ₂)+0.32(%O ₂)+0.28(%N ₂)	g/gmol	28.84	28.84	28.84
Molecular weight of stack gas (wet), M_s				
M _s = M _d (1 - (R _{wv} /100)) + 18(R _{wv} /100)	g/gmol	28.83	28.83	28.79
Velocity of stack gas, V_s				
Pitot tube velocity constant, K _p	-	34.97	34.97	34.97
Velocity pressure coefficient, C _p	-	0.90	0.90	0.90
Average of velocity heads, ΔP _{avg}	mmH ₂ O	8.06	7.61	8.39
Average square root of velocity heads, √ΔP	√mmH ₂ O	2.84	2.76	2.90
Average stack gas temperature, T _s	°C	46.4	54.2	52.0
V _s = ((K _p)(C _p)(√ΔP)(√T _s + 273)) / (√(M _s)(P _s))	m/s	10.74	10.56	11.06
Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO₂}), Dry@O_{2REF} (Q_{stdO₂})				
Area of stack, A _s	m ²	1.23	1.23	1.23
Q _a = (60)(A _s)(V _s)	m ³ /min	790.9	777.7	814.4
Conversion factor (K/mm.Hg), C _f	-	0.3592	0.3592	0.3592
Q _{stw} = ((Q _a)(P _s)(C _f)) / ((T _s) + 273)	m ³ /min	679.0	651.8	687.2
Q _{std} = ((Q _a)(P _s)(C _f)(1 - (R _{wv} /100))) / ((T _s) + 273)	m ³ /min	678.5	651.0	684.1
Q _{stwO₂} = ((Q _a)(P _s)(C _f)) / ((T _s) + 273) / (O _{2REFw})	m ³ /min	N/A	N/A	N/A
Q _{stdO₂} = ((Q _a)(P _s)(C _f)(1 - (R _{wv} /100))) / ((T _s) + 273) / (O _{2REFd})	m ³ /min	N/A	N/A	N/A
Percent isokinetic, %I				
Nozzle diameter, D _n	mm	5.98	5.98	5.98
Nozzle area, A _n	mm ²	28.09	28.09	28.09
Total sampling time, q	min	64	64	64
%I = (4.6398E ⁶)(T _s +273)(V _{mstd}) / (P _s)(V _s)(A _n)(q)(1 - (R _{wv} /100))	%	102.7	102.9	103.2

HYDROGEN FLUORIDE: SAMPLING DETAILS

Sample Runs

Parameter	Units	Run 1	Run 2	Run 3
Sampling Times	-	10:14 - 11:18	11:24 - 12:28	12:32 - 13:36
Sampling Dates	-	13/04/2026	13/04/2026	13/04/2026
Sampling Device	-	ISO	ISO	ISO
Volume Sampled (REF)	m ³	1.0211	0.9817	1.0339
Laboratory Result for Front Impingers	µg/ml	< 0.05	< 0.05	0.14
Laboratory Result for Back Impinger	µg/ml	< 0.05		
Volume in Front Impingers	ml	201.4	323.2	313.6
Volume in Back Impinger	ml	101.3		
Mass in Front Impingers	µg	< 10.1	< 16.2	43.9
Mass in Back Impinger	µg	< 5.1		
Total Mass Collected	µg	< 15.1	< 16.2	43.9
Calculated Concentration	mg/m ³	< 0.015	< 0.016	0.042

Where: ISO stands for Manual Isokinetic Sampling Train

Blank Runs

Parameter	Units	Blank 1
Blank Dates	-	13/04/2026
Average Volume Sampled (REF)	m ³	1.0122
Laboratory Result for Impingers	µg/ml	< 0.05
Volume in Impingers	ml	306.2
Total Mass Collected	µg	< 15.3
Calculated Concentration	mg/m ³	< 0.015

HYDROGEN FLUORIDE: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

Leak Test Results	Units	Run 1	Run 2	Run 3
Mean Sampling Rate	l/min	17.0	16.5	17.7
Pre-Sampling Leak Rate	l/min	0.12	0.12	0.12
Post-Sampling Leak Rate	l/min	0.12	0.12	0.12
Allowable Leak Rate	l/min	0.34	0.33	0.35
Leak Test Acceptable	-	Yes	Yes	Yes

Absorption Efficiency	Units	Run 1
Absorption Efficiency	%	100.0
Allowable Absorption Efficiency	%	N/A ²
Absorption Efficiency Acceptable	-	Yes ²

² The concentration is less than 30% of the ELV, therefore no assessment against an allowable efficiency is required.

Water Droplets	Units	Run 1	Run 2	Run 3
Are Water Droplets Present	-	No	No	No

MU (Concurrent Water Vapour)	Units	Run 1	Run 2	Run 3
Measurement Uncertainty (MU)	%	20.3	12.9	6.2
Allowable MU	%	20.0	20.0	20.0
MU Acceptable	%	No	Yes	Yes

Silica Gel (Concurrent Water Vapour)	Units	Run 1	Run 2	Run 3
Less than 50% Faded	%	Yes	Yes	Yes

Isokinetic Criterion Compliance	Units	Run 1	Run 2	Run 3
Isokinetic Variation	%	102.7	102.9	103.2
Allowable Isokinetic Range	%	95 - 115	95 - 115	95 - 115
Isokineticity Acceptable	-	Yes	Yes	Yes

Filter Temperatures	Units	Run 1	Run 2	Run 3
Maximum Filter Temperature	°C	46	54	52

Test Conditions	Units	Run 1	Run 2	Run 3
Ambient Temperature Recorded?	-	Yes	Yes	Yes

HYDROGEN FLUORIDE: QUALITY ASSURANCE

(PAGE 2 OF 2)

Blank Runs

Leak Test Results	Units	Blank 1	
Expected Sampling Rate	l/min	18.0	
Pre-Sampling Leak Rate	l/min	0.13	
Post-Sampling Leak Rate	l/min	0.13	
Allowable Leak Rate	l/min	0.36	
Leak Test Acceptable	-	Yes	

Validity of Blank vs ELV	Units	Blank 1	
Allowable Blank	mg/m ³	0.1	
Blank Acceptable	-	Yes	

Method Deviations

Nature of Deviation	Run Number			
	(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1	2	3

HYDROGEN FLUORIDE: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value				Standard uncertainty				
	Symbol	Run 1	Run 2	Run 3	Symbol	Units	Run 1	Run 2	Run 3
Sampled Volume (Actual)	V _m	1.1670	1.1360	1.2140	uV _m	m ³	0.0233	0.0227	0.0243
Sampled Gas Temperature	T _m	292.5	296.1	300.6	uT _m	K	2.00	2.00	2.00
Sampled Gas Pressure	ρ _m	101.8	101.8	101.8	uρ _m	kPa	0.50	0.50	0.50
Sampled Gas Humidity	H _m	0.00	0.00	0.00	uH _m	% v/v	1.00	1.00	1.00
Leak	L	0.71	0.73	0.68	uL	%	-	-	-
Laboratory Result	L _r	2.40	2.40	2.40	uL _r	%	-	-	-

Measured Quantities	Uncertainty as a Percentage				Requirement of Standard
	Units	Run 1	Run 2	Run 3	
Sampled Volume (Actual)	%	2.00	2.00	2.00	≤2%
Sampled Gas Temperature	%	0.68	0.68	0.67	≤1%
Sampled Gas Pressure	%	0.49	0.49	0.49	≤1%
Sampled Gas Humidity	%	1.00	1.00	1.00	≤1%
Leak	%	0.71	0.73	0.68	≤2%
Laboratory Result	%	2.40	2.40	2.40	No Requirement

Measured Quantities	Uncertainty in Measurement Units					Sensitivity Coefficient		
	Symbol	Units	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3
Sampled Volume (STP)	V _m	m ³	1.0211	0.9817	1.0339	0.01	0.02	0.04
Leak	L	mg/m ³	0.0001	0.0001	0.0002	1.00	1.00	1.00
Laboratory Result	L _r	mg/m ³	0.0004	0.0004	0.0010	1.00	1.00	1.00

Measured Quantities	Uncertainty in Result			
	Units	Run 1	Run 2	Run 3
Sampled Volume (STP)	mg/m ³	0.0004	0.0004	0.0011
Leak	mg/m ³	0.0001	0.0001	0.0002
Laboratory Result	mg/m ³	0.0004	0.0004	0.0010

Measured Quantities	Oxygen Correction Part of MU Budget			
	Units	Run 1	Run 2	Run 3
O ₂ Correction Factor	-	N/A	N/A	N/A
Stack Gas O ₂ Content	% v/v	N/A	N/A	N/A
MU for O ₂ Correction	-	N/A	N/A	N/A
Overall MU For O ₂ Measurement	%	N/A	N/A	N/A

Parameter	Units	Run 1	Run 2	Run 3
Combined uncertainty	mg/m ³	0.001	0.001	0.002
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.001	0.001	0.003
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A	N/A	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.001	0.001	0.003
Reported Uncertainty	mg/m ³	0.001	0.001	0.003
Expanded uncertainty (95% confidence), without Oxygen Correction	%	7.0	7.1	7.1
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A	N/A	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	7.0	7.1	7.1
Reported Uncertainty	%	7.0	7.1	7.1
Reported Uncertainty as % of ELV	%	0.1	0.1	0.3

TOTAL VOCs (as CARBON): RESULTS SUMMARY

Avon Metals Ltd, Gloucester
A1 New GT

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m ³	7.2	7.2
Uncertainty	±mg/m ³	0.44	0.44
Mass Emission	g/hr	288	288
Uncertainty	±g/hr	33.0	33.0

General Sampling Information


Parameter	Value	
Standard	EN 12619:2013	
Technical Procedure	MD 020	
Probe Material	Stainless Steel	
Filtration Type / Size	2µm Stainless Steel and 0.1µm Glass Fibre	
Heated Head Filter Used	Yes	
Heated Line Temperature	180°C	
Span Gas Type	Propane In Synthetic Air (5 Grade)	
Span Gas Reference Number	A0096760	
Span Gas Expiry Date	05/03/2031	
Span Gas Start Pressure (bar)	180	
Gas Cylinder Concentration (ppm)	81.6	
Span Gas Set Point (ppm)	81.60	
Span Gas Uncertainty (%)	1.77	
Zero Gas Type	Synthetic Air (5 Grade)	
Number of Sampling Lines Used	1 / 1	FORMAT: Number Used / Number Required
Number of Sampling Points Used	1 / 1	FORMAT: Number Used / Number Required
Sample Point I.D.'s	A1	

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas.

TOTAL VOCs (as CARBON): DATA TREND

Graphical Trend of Data



TOTAL VOCs (as CARBON): SAMPLING DETAILS & QUALITY ASSURANCE

Sampling Details

Parameter	Units	Run 1
Sampling Times	-	11:24 - 12:24
Sampling Dates	-	13/04/2026
Instrument Range	ppm	100
Span Gas Value	ppm	81.6

Quality Assurance

	Zero Drift	Units	Run 1
CAL 1	Zero Down Sampling Line (Pre)	ppm	0.00
	Zero Down Sampling Line (Post)	ppm	0.00
	Zero Drift	ppm	0.00
	Zero Drift	%	0.00
	Drift Correction Applied	2-5%	No
	Allowable Zero Drift	± ppm	4.08
	Zero Drift Acceptable	-	Yes

	Span Drift	Units	Run 1
CAL 1	Span Down Sampling Line (Pre)	ppm	81.50
	Span Down Sampling Line (Post)	ppm	81.20
	Span Drift	ppm	-0.30
	Span Drift	%	-0.37
	Drift Correction Applied	2-5%	No
	Allowable Span Drift	± ppm	4.08
	Span Drift Acceptable	-	Yes

	Test Conditions	Units	Run 1
	Run Ambient Temperature Range	°C	12 - 13

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run)	1
There are no deviations associated with the sampling employed.	x

TOTAL VOCs (as CARBON): MEASUREMENT UNCERTAINTY CALCULATIONS

Performance characteristics	RUN 1	Units
Limit value	10.0	mg/m ³ (REF)
Allowable MU	15.0	%
Measured concentration	7.18	mg/m ³ (STP, dry)
Range Used	100.0	ppm
Range Used [A]	160.6	mg/m ³
Cal gas conc.	81.6	ppm
Conversion	1.61	ppm to mg/m ³
MCERTS Range [B]	15.0	mg/m ³
Lower of [A] or [B]	15.0	mg/m ³
Cal gas conc.	131.1	mg/m ³

Performance characteristics	RUN 1	Units
Response time	45	seconds
Number of readings in measurement	60	-
Repeatability at zero	2.00	% full scale
Repeatability at span level	0.00	% full scale
Deviation from linearity	0.05	% of value
Zero drift	0.00	% full scale
Span drift	-0.37	% full scale
Volume or pressure flow dependence	1.60	% of full scale
Atmospheric pressure dependence	0.30	% of value/kPa
Ambient temperature dependence	1.40	% full scale/10K
Combined interference	0.45	% range
Dependence on voltage	0.50	% full scale/10V
Losses in the line (leak)	0.12	% of value
Uncertainty of calibration gas	1.77	% of value

Performance characteristic	RUN 1	Units
Standard deviation of repeatability at zero	use rep at span	mg/m ³
Standard deviation of repeatability at span level	0.00	mg/m ³
Lack of fit	0.00	mg/m ³
Drift	-0.02	mg/m ³
Volume or pressure flow dependence	0.00	mg/m ³
Atmospheric pressure dependence	0.01	mg/m ³
Ambient temperature dependence	0.20	mg/m ³
Combined interference (from MCERTS Certificate)	0.04	mg/m ³
Dependence on voltage	0.06	mg/m ³
Losses in the line (leak)	0.01	mg/m ³
Uncertainty of calibration gas	0.07	mg/m ³

Measurement uncertainty	Result	RUN 1	Units
Combined uncertainty		7.18	mg/m ³
Expanded uncertainty		0.23	mg/m ³
Expanded uncertainty	k = 1.96	0.44	mg/m ³
Uncertainty corrected to std conds. (O ₂)		0.44	mg/m ³ (REF)

	RUN 1	Units
Expanded uncertainty (no O ₂) - at 95% Confidence	6.20	% of Value
Expanded uncertainty (no O ₂) - at 95% Confidence	4.45	% at ELV
Overall Allowable uncertainty (no O ₂) - at 95% Confidence	15.0	% at ELV
Result of Compliance with Uncertainty Requirement	COMPLIANT	-

	RUN 1	Units
Expanded uncertainty (with O ₂) - at 95% Confidence	N/A	% of Value
Expanded uncertainty (with O ₂) - at 95% Confidence	N/A	% at ELV
Overall Allowable uncertainty (with O ₂) - at 95% Confidence	N/A	% at ELV
Result of Compliance with Uncertainty Requirement	N/A	-

Requirement for SRM is that Uncertainty should be <15% of the value at the ELV, on a dry gas basis, or if O₂ correction is applied less than 15% + the uncertainty associated with the O₂ correction (using sqrt of sum squares to add uncertainty components).

VERSION HISTORY

Version Number	Record of changes made within this version of the document
V1	The original document issued to the client